

Spill Summary Report for NRC Report #1140226

Report Date: 9/14/2022

Report Time: 4:05 PM EDT

Region II Hotline Log Entry Information

Data ID: 1910018

Date Of Report: 2/10/2016

NRC #: 1140226

State #: 1510878

ERNS #:

Material Type: Oil

Receiver: D'Onofrio

Material / Amount:

OIL, MISC: MINERAL (NON PCB) (800 GALLON(S));

Location:

Street:
City: QUEENS
County: QUEENS
State: NY
Latitude:
Longitude:

Source of Pollution:

CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body:

Unknown at this time

State Or EPA Responded:

NYSDEC Follow - Up

Initial EPA Action:

No Response at This Time

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 0907255

Date: 2/10/2016	Time: 19:45	
Duty Officer/Responder Name: D'Onofrio	NRC Report #: 1140226	Hotline Log DataID: 1910018
Action Information		
Description: Con Ed is currently searching for 3 different potential transmission line leaks. Since this one is possibly leaking at 20 gallons per hour, they will be re-allocating resources to focus on this leak to try to find it's location. Currently the cause of these leaks is unknown. Con Ed will likely have Ken's Marine searching the waterfront to look for signs of the leak in the early am when water operations can be effective.		
Follup-Up:		
Person Contacted		
Name: Paul Didominico Organization: Con Ed Environmental Desk Phone #: 212-580-8383		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any
applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1140226

INCIDENT DESCRIPTION

**** THIS IS A POTENTIAL RELEASE ****

*Report taken by: MST2 ERIC MERRITT at 19:08 on 10-FEB-16

Incident Type: PIPELINE

Incident Cause: UNKNOWN

Affected Area:

Incident was discovered on 10-FEB-16 at 18:50 local incident time.

Affected Medium: UNKNOWN

REPORTING PARTY

Name: MIKE BETO

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE

ASTORIA, NY 11105

Email Address: betoM@coned.com

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: MIKE BETO

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE

ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

RAINEY SUB STATION County: QUEENS

City: QUEENS State: NY
EAST 75TH ST TO THE SUB STATION IN MANHATTEN

POTENTIALLY RELEASED MATERIAL(S)

CHRIS Code: OMN Official Material Name: OIL, MISC: MINERAL
Also Known As: OIL, MISC: MINERAL (NON PCB)
Qty Released: 800 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

CALLER STATED THAT A LEAK ALARM SOUNDED ON THE FEEDER SYSTEM. THE ALARM REGISTERED A LOSS IN PRESSURE WHICH CALCULATED TO A LOSS OF 800 GALLONS OF DIELECTRIC FLUID (NON PCB) FROM THE PIPELINE BETWEEN THE RAINEY SUBSTATION AND THE MANHATTAN STATION. THEY ARE IN THE PROCESS OF TRYING TO VERIFY IF A LEAK IN FACT OCCURRED.

INCIDENT DETAILS

Pipeline Type: TRANSMISSION
DOT Regulated: UNKNOWN
Pipeline Above/Below Ground: BELOW
Exposed or Under Water: NO
Pipeline Covered: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:
Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air:	N		
Road:	N		Major Artery: N
Waterway:	N		
Track:	N		

Passengers Transferred: NO
Environmental Impact: UNKNOWN
Media Interest: UNKNOWN Community Impact due to Material:

REMEDIAL ACTIONS

ATTEMPTING TO LOCATE THE POSSIBLE LEAK.
Release Secured: UNKNOWN
Release Rate: 20 GALLON(S) per MINUTE
Estimated Release Duration:

WEATHER

Weather: OVERCAST, 35 1/2 F Wind speed: 16 MPH Wind direction:

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)
10-FEB-16 19:17 (770)4887100
DHS PROTECTIVE SECURITY ADVISOR (PSA DESK)
10-FEB-16 19:17 (703)2355724
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
10-FEB-16 19:17 (202)3661863
U.S. EPA II (MAIN OFFICE)
10-FEB-16 19:24 (732)3214370 DONOFRIO
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
10-FEB-16 19:17 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNESS (COMMAND CENTER)
10-FEB-16 19:17 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
10-FEB-16 19:17 (609)9636900
NOAA RPTS FOR NY (MAIN OFFICE)
10-FEB-16 19:17 (206)5264911
NATIONAL RESPONSE CENTER HQ (AUTOMATIC REPORTS)
10-FEB-16 19:17 (202)2671136

NTSB PIPELINE (MAIN OFFICE)
10-FEB-16 19:17 (202)3146293
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
10-FEB-16 19:17 (518)4577362
PIPELINE & HAZMAT SAFETY ADMIN (OFFICE OF PIPELINE SAFETY (AUTO))
10-FEB-16 19:17 (202)3660568
REPORTING PARTY (RP SUBMITTER)
10-FEB-16 19:17
SECTOR LONG ISLAND SOUND (INTELLIGENCE SECTION)
10-FEB-16 19:17 (203)4684471
SECTOR NEW YORK (COMMAND CENTER)
10-FEB-16 19:20 (718)3544356 YAKUBOV
USCG DISTRICT 1 (COMMAND CENTER)
10-FEB-16 19:17 (617)2238555

ADDITIONAL INFORMATION

INTERNAL REPORT NUMBER 244380.

*** END INCIDENT REPORT # 1140226 ***
Report any problems by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>